

UTILITY OPERATIONS

BYPASS, SPILL OR LEAK REPORTING

Date: Aug 1 / 2023 Time of Call: 8:00 AM

Location of Incident: 46 Mill St Tara

What Happened: Sewage Force main leak, shut down as soon as discovered by operator conducting daily checks. Sewage had come to surface above break and was going across ground to back of lift station building + getting to Sable river. Found a hole in PVC force main from Rock against pipe since original install, Repaired w/ a Rubber Main Repair Clamp

When: _____

Current Status: called SAC (Mark) 17:00 reference # 1-3P2HD2, local MOECC

Laszlo Berti @ 17:08 Public Health Afterhours @ 17:15, Left message at

Greg Souble at 17:21

- Bypass: Yes No
- Spill: Yes No
- Leak: Yes No

Approximate amount: No way to estimate or measure. Not a significant amount was visible.

Current Action: Asst CC

Possible effects on the receiver, environment or downstream user:
Small amount (No way to measure or estimate an actual volume) leaked across ground to Sable river. No downstream users to my knowledge

Further action required: Complete notifications to MOECC on Aug 2/23 + respond to follow up questions

x - Greg Souble follow up with me at 8:40am (Wed) Carl Seider

Prepared by: Chris Leage

Representing: Arran - Elderslie